

### Three Mile Creek - Quarterly Compliance

Date	Site	pH	Conductivity mS/m	Nitrite	Nitrate	Ammonia Nitrogen	DRP	E. coli (cfu/100mL)	Temperature
8/05/2019	Site A: 430 meters Upstream	6.2	140.1	0.002	0.007	0.14	0.5	310	17.6
8/05/2019	Site B: 150 meters Upstream	6.4	145.7	0.003	0.024	0.21	0.5	210	18.6
8/05/2019	Site C: 50 metres downstream	6.9	368.4	0.062	2.4	0.18	2.7	150	17.7
6/08/2019	Site A: 430 meters Upstream	6.1	122.7	0.002	0.89	0.03	0.5	19	23.6
6/08/2019	Site B: 150 meters Upstream	6.2	130.2	0.003	0.91	0.05	0.5	11	23.5
6/08/2019	Site C: 50 metres downstream	6.5	164.4	0.008	1.07	0.07	0.5	430	23.2
13/11/2019	Site A: 430 meters Upstream	6.5	129.3	0.002	0.134	0.13	0.5	2250	20.3
13/11/2019	Site B: 150 meters Upstream	6.6	133.8	0.003	0.118	0.14	0.5	340	20.8
13/11/2019	Site C: 50 metres downstream	7	247.5	0.021	0.147	0.36	1	180	20.5
10/02/2020	Site A: 430 meters Upstream	6.8	239.9	0.005	0.011	0.51	0.5	2200	19.3
10/02/2020	Site B: 150 meters Upstream	7.4	554.4	0.048	0.058	3.2	0.5	1500	19.2
10/02/2020	Site C: 50 metres downstream	7.4	628.8	0.033	0.078	4.7	1.6	450	19.4
10/02/2020	Site A: 430 meters Upstream	7	231.3	0.005	0.012	0.46	0.5	1600	18.3
10/02/2020	Site B: 150 meters Upstream	7.4	594.1	0.036	0.045	3.8	0.8	450	17.8
10/02/2020	Site C: 50 metres downstream	7.4	624.2	0.034	0.059	5.2	1.6	730	18.4
13/05/2020	Site A: 430 meters Upstream	5.6	486.4	0.002	0.032	0.17	0.5	4	22.8
13/05/2020	Site B: 150 meters Upstream	6.8	364.2	0.116	0.31	0.56	0.5	390	22.8
13/05/2020	Site C: 50 metres downstream	7.1	601.6	0.54	3.8	1.2	3.1	190	22.1
19/08/2020	Site A: 430 meters Upstream	5.7	174.1	0.002	0.58	0.09	0.5	4	18.3
19/08/2020	Site B: 150 meters Upstream	5.8	192.9	0.002	0.54	0.09	0.5	31	18.3
19/08/2020	Site C: 50 metres downstream	6.4	219.7	0.012	0.57	0.2	0.7	23	16.4

**\*\*\* Locations is distance from WWTP discharge point \*\*\***